


GENERAL NOTES:

1. NO MORE THAN 700 SQ. FT. OF ROOF AREA MAY BE DRAINED TO A SINGLE SPLASH BLOCK.
2. SPLASH BLOCK SHALL DRAIN TO A MINIMUM OF 50 FT. OF WELL ESTABLISHED VEGETATION. IF LESS THAN 50 FT OF WELL ESTABLISHED VEGETATION IS PRESENT THEN THE SPLASH BLOCK MUST DISCHARGE TO ROCK LEVEL SPREADER (SEE DETAIL EC-6.00)

" NOT TO SCALE "

	<b>TOWN OF CHAPEL HILL</b> STANDARD DETAIL	
	REVISIONS 05/2024	<h1>SPLASH BLOCK</h1>
DATE: 02/2017		
		<h2>EC-5.00</h2>

\\chfs\Engineering\Design Manual\Standard Details for 2023 Revision\CAD\CAD details\EC-500.dwg