



- NOTES:**
1. CONTRACTOR IS RESPONSIBLE FOR RE-ESTABLISHING ALL SLOPES DISTURBED BY CONSTRUCTION.
 2. NO ABOVE GROUND UTILITIES OR UTILITY SURFACE COVERS/PLATES/MANHOLES SHALL BE LOCATED WITHIN TRAIL AND SHALL BE MINIMUM 2 FEET FROM THE EDGE OF TRAIL. RAISED MANHOLES SHALL BE MINIMUM 4 FEET FROM TRAIL EDGE.
 3. ALL TRAILS SHALL BE LOCATED MINIMUM 5 FEET FROM THE BACK OF CURB.
 4. SIDE SLOPES SHALL NOT EXCEED 3:1. CUT & FILL SLOPES SHALL TIE INTO EXISTING SLOPES TO CREATE AN EVEN TRANSITION.
 5. CROSS SLOPE TYPICALLY TO LOW SIDE BUT CROSS SLOPE TO INSIDE OF DOWNHILL CURVES, WITH GRADUAL TRANSITIONS BETWEEN ANY CROSS SLOPE DIRECTION CHANGES.
 6. PLACE SAWCUT CONTRACTION JOINTS 10' O.C. PERPENDICULAR OF TRAIL.
 7. PLACE DOWELED EXPANSION JOINTS 10' O.C. PERPENDICULAR OF TRAIL.



TOWN OF CHAPEL HILL
 STANDARD AND SPECIFICATIONS

STANDARD 10-FT ASPHALT GREENWAY TRAIL

PR-4.00

DATE 02/2017

" NOT TO SCALE "