



- TREE PIT CONSISTS OF STRUCTURAL SOIL 24" DEEP WITHIN LIMITS SHOWN ON THE PLAN.
- STRUCTURAL SOIL IS 70% STALITE ½ EXPANDED AGGREGATE AND 30% SANDY LOAM.

SIDEWALK NOTE:

- 3000 PSI WITH FIBER
- CONTROL JOINTS TOOLED PERPENDICULAR TO BUILDINGS APPROXIMATELY EVERY 5-6' ±
- MAXIMUM CROSS SLOPE 2% (1/4" FALL/FT)
- C JOINT SAW-CUT PARALLEL TO BUILDINGS
- STAMPED 'TCH' AT SIDEWALK EDGE WHERE DUCT BANK TURN-OUT CROSSES.

WALL NOTES:

- WHOLE BRICKS SHALL BE USED IN ROWLOCK CAP AT RETAINING WALL CORNERS WITH A PAVER BRICK ON THE END OF A ROW OF CORE BRICKS, NO BEVELED CUT BRICKS AT RETAINING WALL CORNER.



DATE: 02/2017

**TOWN OF CHAPEL HILL
STANDARD DETAIL**

REVISIONS

**BRICK RETAINING
WALL WITH TREE PIT**

SS-4.00

" NOT TO SCALE "