



- NOTES:**
1. EITHER SOLID BRICK, SOLID BLOCK, OR PRECAST CONCRETE MAY BE USED.
 2. FOR 24 INCH R.C.P. AND LARGER USE PIPE DIAMETER PLUS 12 INCHES FOR MINIMUM INSIDE DIMENSION.
 3. GRATED INLETS SHALL NOT BE USED WITHIN TRAVEL AREAS.
 4. STEPS ON CENTER. 1ST STEP IS 2 FEET FROM TOP.
 5. WHERE STEPS ARE REQUIRED, USE OF PRECAST CONCRETE SLAB SHALL BE USED AS TOP AND GRATE POSITIONED OVER STEPS.
 6. YARD INLETS DEEPER THAN 10 FEET SHALL REQUIRE DOUBLE WALLS.

" NOT TO SCALE "



DATE: 02/2017

TOWN OF CHAPEL HILL
STANDARD DETAIL

REVISIONS

STANDARD YARD
INLET WITH GRATE
AND FRAME

SW-7.00