



**NOTE:**

1. 8.33% (12:1) MAX RAMP SLOPE
2. CROSS SLOPE: 2.00%
3. CURB RAMPS REQUIRE A (4'-0") MINIMUM LANDING WITH A MAXIMUM CROSS SLOPE AND LONGITUDINAL SLOPE OF 2.00% WHERE PEDESTRIANS PERFORM TURNING MANEUVERS. SLOPE TO DRAIN TO CURB.
4. CONSTRUCT THE WINGS (X) WITH A CURB FACE SLOPE 12:1 OR HIGHER.
5. PLACE TRUNCATED DOME FINISH ON THE RAMP PARALLEL WITH THE CURB.
6. PLACE CONTRACTION JOINTS AND EXPANSION JOINTS SCORELINES AS SHOWN.
7. OPTIONAL BACKING CURB FOR LANDSCAPE SUPPORT.

**TYPE 2A**  
(COMMERCIAL/RETAIL USE)



DATE: 02/2017

**TOWN OF CHAPEL HILL**  
STANDARD DETAIL

REVISIONS

**CURB RAMP**  
**TYPE 2A**

**T-2.03**

" NOT TO SCALE "